



POLYETHYLENE PLASTIC PIPE LINER FIELD SECTION 2015

2015.1 SCOPE. To establish procedures for inspecting and reporting of polyethylene plastic pipe liners. The specification requirements are set forth in the bid request issued by the Department.

2015.2 APPARATUS.

- (a) Rule with suitable graduations to accurately measure the material to be inspected.

2015.2 PROCEDURE.

2015.2.1 Inspection. Field inspection is to include checking of inside diameter of the liner, workmanship and marking. If field inspection indicates questionable compliance, the Division Engineer is to be consulted.

2015.2.2 Sampling. Samples for laboratory testing are only to be taken when directed by the Division Engineer, Materials.

2015.3 CERTIFICATION.

2015.3.1 The supplier shall furnish a manufacturer's certification at destination stating that the pipe liner being furnished was manufactured and tested in accordance with the specifications and was found to comply with the requirements of the specifications. A copy of the certification shall be attached to the inspection report.

2015.4 REPORT.

2015.4.1 Form T-634 shall be used to report polyethylene plastic pipe liners. The report shall show the manufacturer, brand name, size and quantity of liner and shall contain appropriate remarks regarding the acceptance of the liner. A copy of the manufacturer's certification shall be attached to the report.

2015.4.2 Use Class B report distribution from [General Sec 7.1.7.2](#).

